

## Article II, Section 30-28 – Definitions

**Wind Energy System, Large:** *A wind energy conversion system consisting of one or more wind turbines, towers and associated control or conversion electronics, having a rated nameplate capacity of not more than 999 kilowatts (kW). For purposes of non-residential net metering, Virginia Code §56-594B limits the electrical generating facility to a capacity of not more than 500 kilowatts (kW).*

**Wind Energy System, Utility:** *A wind energy conversion system consisting of more than one wind turbine, towers and associated control or conversion electronics, having a rated nameplate capacity of 1 megawatt (MW) or greater.*

## Article III – District Regulations

SEC. 30-32. - AG-3 AGRICULTURAL/RURAL PRESERVE DISTRICT.

Sec. 30-32-2. - Permitted Uses.

(B) Special Use Permit

5. *Miscellaneous Uses*

***Wind Energy System, Large\****

***Wind Energy System, Utility\****

SEC. 30-33. - AG-1 AGRICULTURAL/RURAL LOW DENSITY DISTRICT.

Sec. 30-33-2. - Permitted Uses.

(B) Special Use Permit

6. *Miscellaneous Uses*

***Wind Energy System, Large\****

***Wind Energy System, Utility\****

SEC. 30-61. - I-1 LOW INTENSITY INDUSTRIAL DISTRICT.

Sec. 30-61-2. - Permitted Uses.

(B) Special Use Permit

3. *Miscellaneous Uses*

***Wind Energy System, Large\****

***Wind Energy System, Utility\****

SEC. 30-62. - I-2 HIGH INTENSITY INDUSTRIAL DISTRICT.

Sec. 30-62-2. - Permitted Uses.

(B) Special Use Permit

4. *Miscellaneous Uses*

***Wind Energy System, Large\****

***Wind Energy System, Utility\****

## **Article IV – Use and Design Standards**

### ***SECTION 30-87-7. Wind Energy System, Large; and Wind Energy System, Utility***

(A) ***Purpose and Intent:*** *The purpose of this ordinance is to provide regulations for the placement, design, construction, monitoring, operation, modification, and removal of large wind energy systems and utility wind energy systems, while addressing public safety, minimizing impacts on scenic, natural and historic resources of the County and not unreasonably interfering with the development of independent renewable energy sources.*

(B) ***General Standards:***

1. ***Type of Tower:*** *The tower component of any large wind energy system or utility wind energy system shall be one of monopole design that is recommended and certified by the manufacturer.*
2. ***Tower Color:*** *Any large wind energy system or utility wind energy system tower shall maintain a white or galvanized steel finish, unless Federal Aviation Administration (FAA) standards require otherwise. The Board of Supervisors may allow a property owner, who is attempting to conform the tower to the surrounding environment and architecture, to paint the tower to reduce its visual obtrusiveness.*

3. **Setbacks:** Large wind energy systems and utility wind energy systems shall be set back a ~~minimum~~ distance of ~~one hundred ten percent (110%)~~ **four hundred percent (400%)** of the height of the wind energy system from all adjoining non-participating property lines. The Board of Supervisors may ~~increase~~ **modify** the ~~minimum~~-required setbacks as appropriate, based on site specific considerations during the special use permit process.
4. **Separation:** The minimum distance required between towers shall be established during the special use permit process by the Board of Supervisors.
5. **Noise:** Large wind energy systems and utility wind energy systems shall not exceed ~~60~~ **40** decibels (dba), as measured at the closest non-participating property line, except during **short-term events (define parameters)** such as **severe windstorms (define parameters)**. An analysis, prepared by an acoustical engineer with a professional engineering license in the Commonwealth of Virginia, shall be provided to demonstrate compliance with this noise standard. Based upon site specific considerations, the Board of Supervisors may ~~increase~~ **modify** the decibel level during the special use permit process. **Low frequency standard?**
6. **Shadowing/Flicker:** Large wind energy systems and utility wind energy systems shall be sited in a manner that minimizes shadowing and flicker impacts. The applicant has the burden of proving that this effect does not have significant adverse impacts on neighboring or adjacent uses through the appropriate siting of the facility or through mitigation.
7. **Lighting:** Large wind energy systems and utility wind energy systems shall not be artificially lighted unless required by the Federal Aviation Administration (FAA) or an appropriate authority.
8. **Electromagnetic Communication Interference:** ~~The applicant shall ensure that there will be no~~ Large wind energy systems and utility wind energy systems shall be sited in a manner that minimizes the disruption or loss of radio, telephone, television or similar signals ~~or service~~. If loss or disruption occurs ~~due to the operation of the large wind energy system or utility wind energy system~~, the applicant shall be required to provide appropriate mitigation measures to ensure that the signal ~~or service~~ is restored **within \_\_\_\_\_ hours**.
- 9.(a) **Airports.** No large wind energy systems and utility wind energy systems ~~within two (2) miles from a general or commercial airport or located at a ground elevations at or above two thousand (2,000) feet, average mean sea level,~~ shall be constructed unless the applicant has i.) first completed and submitted a Federal Aviation Administration Form 7460-1 to ~~shall be referred to the appropriate regional office of the Federal Aviation Administration (FAA) for the preparation of an aeronautical study and~~

*determination of there being no Hazard to Air Navigation review and comment prior to filing an application for a special use permit; and ii.) has provided a copy of the completed FAA Form 7460-1, including all attachments and the FAA's case study number to the Executive Director of the Roanoke Regional Airport Commission, and has received a written determination as to whether the proposed system would create adverse impacts on current and/or future airport operations, or on anticipated improvements to the airport or its navigational aids.*

***10.(b) Zoning Overlay Districts. Large wind energy systems and utility wind energy systems shall comply with any additional requirements established in the airport overlay district in Section 30-72 of this ordinance, and the emergency communications overlay district in Section 30-73.***

***911. Advertising: Signs, writing, pictures, flags, streamers, or other decorative items that may be construed as advertising are prohibited on wind energy systems, except as follows:***

- (a) Manufacturer's or installer's identification on the wind turbine, and*
- (b) Appropriate warning signs and placards.*

***102. Speed Controls: Large wind energy systems and utility wind energy systems shall be equipped with manual (electronic or mechanical) and automatic overspeed controls to limit the blade rotation speed to within the design limits of the wind energy system.***

***113. Land clearing, soil erosion and habitat impacts: Clearing of natural vegetation shall be limited to that which is necessary for the construction, operation and maintenance of the wind facility. Adherence to Erosion and Sediment Control regulations is required. The restoration of natural vegetation in areas denuded for construction activities shall be required so long as the restored vegetation does not interfere with the operation of the wind energy system or the maintenance thereof.***

***124. Monitoring and Maintenance: The applicant shall maintain large wind energy systems and utility wind energy systems in good condition. Such maintenance shall include, but not be limited to, painting, structural integrity of the foundation and support structure and security barrier (if applicable), and maintenance of the buffer areas and landscaping if present. Site access shall be maintained to a level acceptable to the Zoning Administrator in accordance with the County's Fire Access Code. The project owner shall be responsible for the cost of maintaining the large wind energy system and the utility wind energy system and access roads, unless accepted as a public way, and the cost of repairing any damage occurring as a result of operation and construction.***

**135. Removal of Defective or Abandoned Large Wind Energy Systems or Utility Wind Energy Systems**

- (a) *At such time that a large wind energy system or utility wind energy system is scheduled to be abandoned or discontinued, the owner shall notify the Zoning Administrator by certified U.S. mail of the proposed date of abandonment or discontinuation of operations.***
- (b) *Within 180 days of the date of abandonment or discontinuation, the owner shall physically remove the large wind energy system or utility wind energy system. This period may be extended at the request of the owner and at the discretion of the County. Physically remove shall include but not be limited to:***

  - i. Removal of the wind turbine and tower, all machinery, equipment, equipment shelters, security barriers and all appurtenant structures from the subject property;***
  - ii. Proper disposal of all solid or hazardous materials and wastes from the site in accordance with local and state solid waste disposal regulations;***
  - iii. Restoration of the location of the large wind energy system or utility wind energy system to its natural preexisting condition, except that any landscaping or grading may remain in the after-condition if a written request is submitted by the landowner to the County.***
  - iv. Foundations shall be removed to a depth of three (3) feet below ground level or covered to an equivalent depth with fill material. At the time of removal, the site shall be restored to its pre-existing condition. If a written request is submitted by the landowner to the County then this requirement may be waived or altered for any other legally authorized use. Restoration shall be verified by the County.***
- (c) *If the large wind energy system or utility wind energy system, or any part thereof, is inoperable for more than 180 days and the owner fails to give such notice to the County, then the large wind energy system or utility wind energy system shall be considered abandoned or discontinued. The County shall determine in its decision what proportion of the large wind energy system or utility wind energy system is inoperable for the wind energy system to be considered abandoned.***
- (d) *Decommissioning:***

  - i. If an applicant fails to remove a large wind energy system or utility wind energy system in accordance with this section of this ordinance, the County shall have the authority to enter the subject property and physically remove the facility. The County shall require the applicant, and/or subsequent owners of the property or large wind energy system or utility wind energy system, to provide a form of surety***

*mutually agreeable to the applicant and the County to cover costs of the removal in the event the County must remove the facility.*

- ii. Prior to obtaining a Certificate of Occupancy and Zoning Compliance from the County and on every tenth (10th) anniversary of the commencement of the commercial operation of the Project, applicant shall provide to the County an estimate of the projected salvage value of the turbines and other equipment to be removed from the Project site ("Salvage Value"), as well as the projected cost of removing the turbines and other equipment from the site as determined by an independent engineer mutually agreeable to the applicant and County ("Gross Decommissioning Cost").*
- iii. Based on this determination, applicant shall post and maintain decommissioning funds in an amount equal to Net Decommissioning Cost, that being Gross Decommissioning Cost minus Salvage value.*
- iv. Decommissioning Funds may be in the form of a performance bond, surety bond, letter of credit, corporate guarantee or other form of financial assurance as may be mutually acceptable to the applicant and the county.*
- v. The Decommissioning Funds shall be posted and maintained with a bonding company or Federal or State chartered lending institution mutually agreeable to the applicant and County.*

**146.** *Compliance with Other Regulations:* *Large wind energy systems and utility wind energy systems shall comply with all applicable local, state and federal regulations.*

**157.** *Application Requirements:*

- (a)** *All potential applicants for a large wind energy system or utility wind energy system shall consult with County staff at least thirty (30) days prior to submitting an application. During this consultation, the applicant shall present information to the County staff regarding the proposed project, its objectives and its potential **site and viewshed** impacts **including potential direct and indirect impacts to a national or state forest, national or state park unit, wildlife management area, or known historic or cultural resource site within five (5) miles of the proposed project.** The staff shall provide the potential applicant with information on County policies and standards for large wind energy systems and utility wind energy systems.*
- (b)** *In addition to the application requirements contained in Section 30-19-2 of this ordinance, all applications for a large wind energy system or utility wind energy system shall provide the following at the time of the application:*

- i. *A detailed concept plan with project location maps that show the location **and clearing limits** of all components of the large wind energy system or utility wind energy system. **Project components include, but are not limited to roads, power lines and other project infrastructure; collector, distribution and transmission lines; temporary or permanent storage lay down areas; substations; and any structures associated with the project.***
- ii. *A description and analysis of existing site conditions, including information on topography, archaeological and historic resources, natural water courses, floodplains, unique natural features, tree cover areas, etc.*
- iii. *Accurate, to scale, photographic simulations showing the relationship of the large wind energy system or utility wind energy system and associated facilities and development (i.e. substation, appurtenances, disturbed areas, etc.) to its surroundings. The photographic simulations shall show such views of wind energy structures from locations such as property lines and roadways, as deemed necessary by the County in order to assess the visual impact of the large wind energy system or utility wind energy system. The total number of simulations and the perspectives from which they are prepared shall be established by County staff at the presubmission consultation required in section 15(a) above. **County staff will work with all national or state forest, national park or state park unit, wildlife management area, or known historic or cultural resource site within five (5) miles of the proposed project to establish which possible observation points and visual simulations will be necessary to represent the most sensitive views from which the project will be visible.***
- iv. *Sound study providing an assessment of pre-construction and post-construction conditions. Additionally, the applicant shall provide documentation regarding noise complaint response procedures and protocol for post-construction monitoring.*
- v. *A phasing schedule for the construction of the large wind energy system or utility wind energy system, including staging areas, off-site storage facilities and transportation routes.*



- vi. *Written verification that all required submittals to the Federal Aviation Administration have been submitted, including a copy of the completed FAA Form 7460-1 and all attachments. A copy of the FAA's written determination of whether the proposed study outcomes of the FAA Obstruction Evaluation for the large wind energy system or utility scale wind energy system would create a Hazard to Air Navigation, as well as the written response of the Executive Director of the Roanoke Regional Airport Commission shall be submitted.*
- vii. *A summary of the wind data gathered for the proposed large wind energy system or utility wind energy system. The dates and periods of the collection of the wind data shall also be submitted. The applicant shall provide access to the wind data for County staff or its consultant(s), as needed.*
- viii. *The ~~applicant~~ County shall provide written notification to the office of a national or state forest, national or state park unit, wildlife management area, or known historic or cultural resource site, if a proposed wind energy system is within five (5) miles of the boundary of the said entity.*
- ix. *Information (including modeling) regarding the impacts from shadowing and shadow flicker for the proposed large wind energy system or utility wind energy system.*
- x. *Additional information as deemed necessary by county staff.*
- (c) *The applicant shall be responsible for all fees associated with the filing of the application including the cost of any independent analysis deemed necessary by the county to verify the need for the large wind energy system or utility wind energy system.*
- (d) *The applicant shall conduct public information meeting(s) to discuss its development plans and obtain community feedback.*